

BACnet CONFORMANCE CERTIFICATE



No. BTL-30034

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.12. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 12.0 and the BTL Test Policies, see Test Report number VG 2015_10605 of MBS.

Product name (B-BC)
BACnet Building Controller E-DDC
Models E-DDC3.2, E-DDC5.0 H, E-DDC-B5.0, E-DDC-B6.0, E-DDC-B9.0, E-DDC3.3, E-DDC3.3S, E-DDC3.4S, E-DDC4.0, ROUTER-GSM, ROUTER-BC, GW-BC-SE, UGW
Software version
03.06.05
Vendor
SE-Elektronik GmbH
Eythstraße 16
73037 Göppingen, Germany

This certificate is valid until **28-Mar-2019**.

28-Mar-2014

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body